

TEST REPORT

REPORT NUMBER: 170418009SHF-BP-4

ORIGINAL ISSUE DATE: 2017-05-09

EVALUATION CENTER

Intertek Testing Services Ltd., Shanghai
Plant 7, No. 6958 Daye Road, Fengxian District, Shanghai, China

RENDERED TO

Taizhou Huali Plastic Co. Ltd.

Zhangdian Industrial Zone, Jiangyan, Jiangsu Prov., P.R.China

PRODUCT EVALUATED

Vinyl Flooring 5mm

EVALUATION PROPERTY

As requested by the applicant, for details refer to attached pages(s).

"This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program."

Report Template Revision Date: 2016/9/1

Test Report

Report Number: 170418009SHF-BP-4

Report Date: 2017-05-09

Applicant:	Taizhou Huali Plastic Co. Ltd.
Applicant Address:	Zhangdian Industrial Zone, Jiangyan, Jiangsu Prov.,P.R.China
Attn:	Bonnie Yuan

Sample information:

Product:	Vinyl Flooring 5mm
Model:	/
Specification:	5mm
Sample Quantity:	2 pcs
Sample ID:	S170418009SHF.002
Date Received:	2017/04/11
Date Test Conducted:	2017/04/18 ~ 2017/05/09

Conclusion:

For details refer to attached page(s).

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.



Test Report

Report Number: 170418009SHF-BP-4

Report Date: 2017-05-09

Test Items, Method and Results:

Test Item	Test Method	Result
Static Coefficient of Friction (Standard Leather)	With reference to ASTM D2047-11 and client's requirement	Dry: 0.37 Wet ¹ : 0.69


Note:

1. ASTM D2047 does not require test under wet condition, test result is only for reference as per the client's requirement.

Appendix A: Sample received photo



Approved by:




Name: Sun Sun

Title: Approver




Name: Sally Xie

Title: Reviewer



Name: Will Tan

Title: Project Engineer

The End of Report

Intertek Testing Services Ltd., Shanghai

No.7 Building, No. 6958 Daye Road, Fengxian District, Shanghai

Tel: 021-61136116 Fax: 021-61189921 Website: www.intertek.com