

# TEST REPORT

**REPORT NUMBER: 170418009SHF-BP-2**

ORIGINAL ISSUE DATE: 2017-05-09

## **EVALUATION CENTER**

Intertek Testing Services Ltd., Shanghai  
Plant 7, No. 6958 Daye Road, Fengxian District, Shanghai, China

## **RENDERED TO**

**Taizhou Huali Plastic Co. Ltd.**

**Zhangdian Industrial Zone, Jiangyan, Jiangsu Prov., P.R.China**

## **PRODUCT EVALUATED**

Vinyl Flooring 5mm

## **EVALUATION PROPERTY**

As requested by the applicant, for details refer to attached pages(s).

*"This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program."*

Report Template Revision Date: 2016/9/1

## Test Report

Report Number: 170418009SHF-BP-2

Report Date: 2017-05-09

**Applicant:** Taizhou Huali Plastic Co. Ltd.

**Applicant Address:** Zhangdian Industrial Zone, Jiangyan, Jiangsu Prov., P.R.China

**Attn:** Bonnie Yuan

### Sample information:

Product: Vinyl Flooring 5mm

Model: /

Specification: 5mm

Sample Quantity: 2 pcs

Sample ID: S170418009SHF.002

Date Received: 2017/04/11

Date Test Conducted: 2017/04/18 ~ 2017/05/09

### Conclusion:

For details refer to attached page(s).

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

## Test Report

**Report Number: 170418009SHF-BP-2**

**Report Date: 2017-05-09**

### **Test Items, Method and Results:**

Test Item: Water absorption

Pre-Condition: (23±2)°C, (50±5)% RH for 24 hours specified by applicant

Test Condition: Submersion in water at (23±1)°C for 24 hours


Test Items	Test Method	Test Results
Water Absorption	ASTM D570-98(R2010) <sup>e1</sup> (Modified)	Water absorption: 0.05 %

## Test Report

Report Number: 170418009SHF-BP-2

Report Date: 2017-05-09


### Appendix A: Sample received photo



### Approved by:

  
Name: Sun Sun  
Title: Approver

  
  
Name: Sally Xie  
Title: Reviewer

  
Name: Will Tan  
Title: Project Engineer

\*\*\*\*\*

The End of Report

Intertek Testing Services Ltd., Shanghai

No.7 Building, No. 6958 Daye Road, Fengxian District, Shanghai

Tel: 021-61136116 Fax: 021-61189921 Website: [www.intertek.com](http://www.intertek.com)